



## **WWTP MONTHLY REPORT FOR SEPTEMBER 2026**

### **Sewer Crew (Collections)**

**PSU- STOP UPS-6**

**POINT REPAIR – 1**

**SHOT LINE DUE TO DEAD END - 0**

**SEWER ODOR - 2**

**MH LID BROKEN OR MISSING-3**

**TELEWISE LINE – 2**

**ASSIST WATER DEPT-1**

**SEWAGE SPILLAGE – 0**

**LIFT STATIONS HIGH LEVEL ALARM-5**

**CUSTOMER REQUEST LINE TO BE SHOT-0**

**WKLY MAINTENANCE SOUTHSIDE UNIT 355**

**WKLY MAINTENANCE NORTHSIDE UNIT 356**

**Sewer Crew has been using the Vactor to jet rodding the sewer lines on sewer maps to clean and maintain lines in the city. Sewer Crew is maintaining RIAC, Kids Care, Mystec, Mescalero lift stations.**

**Total of 6 in Department to include** (2) Sr. Equipment Operators (4) Equipment Operators. (2) Vacant position Positions requires CDL class B with tank and air brake endorsement

South side sewer crew on site at air center during the week of air race's incase of sewer back up's or any other sewer problems. While north side crew handled all calls through out the city.

New Construction of Lift station began in March at RIAC lift station.

Kids Care and Mescalero lift station is serviced and maintained on weekly basis to ensure proper functionality.

### **PLANT OPERATORS**

**Monthly Plant flow –102.59 Million Gallons**

Plant operator makes daily rounds and verifies and collects data of pumps and motors making adjustments to our aeration basins for blowers to maintain ammonia/nitrates and keep a healthy basin and keep plant operational. WWTP operators conduct daily operations to be vital part of treatment of wastewater for the City of Roswell. Maintenance of the entire Wastewater system completed daily by plant operators.

Groundskeeping and watering of lawns for facility has begun with repairs to sprinkler heads. Mowing, edging and weed eating are continuous for 23 acres.

We received the new John Deere front end loader middle of August for operations of turning sludge piles, loading dump truck with spoil piles to haul off to landfill.

**Daily/Regular maintenance as needed on equipment**

**Weekly cleaning of irrigation screens.**

Solids handling utilizing the new dewatering building. Solids handling is a priority for Class A sludge. Temping and turning sludge piles to release sludge to public after lab analyzed for ecoli.

Plant Operators are currently seeking certifications through UOCP (New Mexico Utility Operator Certification Program)

**Total Employees 8**

(1) Sr Operator

(4) WWTP Operators plant operations with one vacancy

(2) Maintenance Worker I maintain grounds and buildings

## **LAB**

**Monthly BAC- T Sampling** – 60 samples required for NMED compliance City of Roswell potable water. (15) Wkly sampling for total of 4 routes for month completed. Quality Control daily analysis for wastewater operations.

**23 Drinking Water Systems** we oversee analysis for DWB compliance to include Alto Lakes Water, Berrendo Water, Capitan Water System, Cumberland, Fambrough, Greenfield, Town of Dexter, Leprino Foods, Roswell Landfill.

We have recently accepted other water systems to include Capitan Water System, Bonito Park Nazarene Camp, Hondo Valley School, Hondo Alsups, Wild Willys RV Park, Generation of Learning, Hobbs Country Club, Pine RV Park, RP RV Park, Morning Side Water, Eileen Acres Service Corps, Midway RV Park, Lone tree bible ranch ,Lincoln MOWCA, Ft.. Stanton Historic Site.

Our lab is a credentialed laboratory for state microbiological samples

### **Monthly intake of microbiological samples**

16-Private Pay (Private Wells and Nice Ice, Artesia Soft Water, Culligan

### **Permit Requirements - DP-281**

Discharging our Effluent water to farmland NMED permit DP-281 requires 3x wkly running BOD5 (biochemical oxygen demand – measure of amount of dissolved oxygen needed by microorganisms to break down organic matter in water sample over a 5day period at 20 C), E-coli, TSS (total suspended solids -dry weight of non-dissolved particles in water sample). Daily analysis of ammonia/nitrate, MLSS (mixed liquor suspended solids-total concentration of suspended solids)

**(15) Monitoring Wells** –3<sup>rd</sup> Quarter sampling completed in July

**Total employees** – 3 (1) Lead Lab Technician (1) Asst. Lab Tech with one vacancy

Lab employees are actively seeking required certifications through NMED.

## **Pretreatment**

### **Completed Domestic Sampling**

**Restaurants -90   Industrial Users -2**

2x Wkly sampling for Covid

Odd months test for **503.13 Sludge Samples**

### **Restaurant sampling for surcharge billing – 2**

Sampling of restaurants was done for: Mi Casita, Martins Capitol Café, Cattle Barrons , Farley, Dunkin Donuts, Vestis

Septic pumpers that were tested were, Johnsons, Demarees, Shiny Boys

Billing surcharge restaurants and Septic pumpers monthly and deposit of checks received. Do follow up on unpaid surcharge billing and also update all files and contact information for the septic pumpers.

### **Monthly billing septic pumpers total of 9 (new pumper Pauley Construction)**

**Flores Rentals, B&D Car Wash, G&A Trucking, Johnson Septic, Demaree, Shiny Boys, Fulkerson Plumbing, RV Village, Pauley Construction**

### **Industrial User Inspections**

**Total employees - (1) Pretreatment coordinator**