Project Type:	Wastewater	Project Code:	QA2

Project Title: Woman Hollering Creek Wastewater Interceptor Main and Lift Station

Project Manager: Engineering

Location Description: FM 1518 near Woman Hollering Creek

Project Summary:

Design and construction of a sanitary sewer system to collect and convey wastewater to the future CCMA water reclamation plant off Trainer
Hale Road in Southern Schertz. The system will consist of approximately 19,000 linear feet of 30" gravity wastewater line running generally
along Woman Hollering Creek from the existing Sedona Lift Station on FM 1518 to a new lift station on IH 10 and approximately 6,000 feet of

force main from the lift station to the CCMA plant. It will also include an additional 18" gravity line approximately 1,500 feet in length that will first serve the Hallie's Cove subdivision. The system is necessary for the new CCMA plant to befin operation and allow the existing Woman Hollering Lift Station at Sedona to be taken out of service.

Start Date: Sep-13

Completion Date: Dec-25

Project Forecast

	Prior Appropriation		2025-26		2026-27		2027-28		2028-29		2029-30		2031-2035		Total Cost	
Funding Source																
Sewer Impact Fees	\$	10,264,789	\$	-	\$	-	\$	-	\$	-	\$	-	\$	-	\$ 1	.0,264,789
Bonds	\$	2,985,000	\$	-	\$	-	\$	-	\$	-	\$	-	\$	-	\$	2,985,000
	\$	-	\$	-	\$	-	\$	-	\$	-	\$	-	\$	-	\$	-
Total Funding Source	\$	13,249,789	\$	-	\$	-	\$	-	\$	-	\$	-	\$	-	\$ 1	3,249,789
		Prior														
Expenditure	E	xpenditure														
Land Acquisition	\$	292,636	\$	-	\$	-	\$	-	\$	-	\$	-	\$	-	\$	292,636
Professional Services	\$	1,520,593	\$	100,000	\$	-	\$	-	\$	-	\$	-	\$	-	\$	1,620,593
Construction	\$	11,236,560	\$	100,000	\$	_	\$	-	\$	-	\$	-	\$	-	\$ 1	1,336,560
Total Expenditure	\$	13,049,789	\$	200,000	\$	-	\$	-	\$	-	\$	-	\$	-	\$ 1	3,249,789

 Project Type:
 Wastewater

 Project Code:
 QA2

Project Title: Woman Hollering Creek Wastewater Interceptor Main and Lift Station

Location:

This product is for informational purposes and may not have been prepared for or be suitable for legal, engineering, or surveying purposes. It does not represent an on-the-ground survey and represents only the

