



March 4, 2016

Mr. Max Bricka  
Director/Purchasing Agent  
901 S. Austin Ave.  
Georgetown, Texas 78626

Subject: Recommendation for IFB 1601-049 – Round Rock Building A & B Parking Lot

Austin Materials is a low bidder for this contract. However, Austin Materials bid the project with a material that did not meet Specification. The following is the Specification comparisons.

	Specification	Austin Materials Proposed Material
<i>Fiber Reinforcement</i>	YES	NONE
<i>Specific Gravity</i>	1.25	1.15
<i>Minimum Residue by Evaporation</i>	52%	50%
<i>Water mixed Per 100 Gallons of Emulsion</i>	4-5 GAL	25-30 GAL
<i>Minimum Application Rate for 3 Coats</i>	0.54 GAL/SY	0.36 GAL/SY

Alpha Paving Industries, LLC is the second low bidder for this contract. After reviewing all of the pertinent information, I recommend to the Commissioner's Court that Williamson County award the construction contract to Alpha Paving Industries, LLC who has proposed to use a material that meets Specification.

Please feel free to contact me if you have any questions or concerns.

Sincerely,

A handwritten signature in blue ink, reading 'J. Terron Evertson'. The signature is fluid and cursive, with a large loop at the end.

J. Terron Evertson, P.E.  
Director of Road and Bridge