

REQ
107903



Proposal

[Phone: 512.929.7090] 1720 Royston Lane, Round Rock, TX 78664 | TACLA021308C | TACLA0020760C | M-18971 | TECL 29725 |

Date: March 14, 2016

Proposal Number: 2016-4060

TXMAS-15-03FAC01

Customer: Williamson County

Attention: Toby Bonnet

Location: Williamson Jail House
306 W 4th Street
Georgetown, TX

Email: tbonnet@wilco.org
Phone: 512-654-1495

Project Name: Boiler Repair

Scope of Work:

- This proposal is to repair the Laars boiler #1 serial #C13247658.
- We will remove the existing heat exchanger and install a new one
- Install new Fire brick walls and 4 burners and burner tray
- We will repipe the inlet and outlet and install 2 circuit setters
- Install a remote Aquastat on tank to operate boilers off and on temperature operation. If it can't be installed on the existing tank we will install it on the hot water supply line to building in the boiler room.
- Install a new T&P (125 PSI @ 210F) valve on tank
- We will move the gas isolation valve so that boiler #2 can continue working while repairs are being made
- After all repairs and piping are complete we will perform a start up on the boiler, check gas pressure settings and confirm all safety features are working properly
- If we find anything wrong during start up we will supply customer with separate proposal for any additional repairs needed

Includes:

- Heat exchanger, new tiles, T&P, pipe, fittings, circuit setters, aquastat and labor

Exclusions:

Overtime, electrical, gas main valve and condition of tank, anything that is not working
Correctly on the boiler outside of the above scope

Quoted Price **\$18,960.00 (excluding tax)**

BW

Prepared by:

Paul Wilson

Email: paul.wilson@csusa.us

Phone: 512-680-2878