



Trimbuilt Construction, Inc.
On time. Every time.

P. O. Box 80169
Austin, TX 78708-0169
(512) 832-1979

Change Request

To: Williamson County
710 Main St.
Georgetown, TX 78626

PH: (512) 943-1599 Fax: (512) 930-3313

Number: 4
Date: 9/14/2017
Project: Wilco WCCHD Office Renovations
Job #: 6148E

Description: Core Structural Beam

We are pleased to offer the following specifications and pricing to make the following changes:

Core a 3" hole through the structural concrete grade beam as directed by the structural engineer in the RFI 04 response in order to run the underground plumbing. This conflict was discovered and a RFI sent on 8/29/17 resulting in a stop of work in the area. Due to the discovery, RFI process, investigation, direction from the design team, pricing the additional work for approval and performance of the solution, the contract duration shall be extended 1 weeks if approval to proceed is received by 9/18/17. New substantial completion date of 1/19/18.

Description:	Price
Plumbing	2,850.00
Insurance	43.00
Profit / Fee	148.00
P & P Bond	72.00
Total:	3,113.00

If you have any questions, please contact me at 512-832-1979.


Submitted by:

Trimbuilt Construction, Inc.

cc:

Approved By:

Date:


9-18-17