



Trimbuilt Construction, Inc.
On time. Every time.

P. O. Box 80169
Austin, TX 78708-0169
(512) 832-1979

Change Request

To: Williamson County
710 Main St.
Georgetown, TX 78626

Number: 7
Date: 10/17/2017
Project: Wilco WCCHD Office Renovations
Job #: 6148E

PH: (512) 943-1599 Fax: (512) 930-3313

Description: Insta Hot Power

We are pleased to offer the following specifications and pricing to make the following changes:

RFI #21 response: add power to insta hots as not originally indicated on the drawings. The panel schedules on the drawings are incorrect with field conditions. Some circuits shown as spare are not. Our electrician had to field investigate and found there is enough capacity in the existing panels to accomodate this change. However, they will be near full capacity once this change occurs.

Because of the differing conditions the circuits the engineer called out on the RFI response will not be used. The circuits to be used are listed on the sub quote.

Description:	Price
Electrical	6,761.00
Insurance	101.00
Profit / Fee	352.00
P & P Bond	172.00
Total:	7,386.00

If you have any questions, please contact me at 512-832-1979.

Submitted by:

Trimbuilt Construction, Inc.

cc:

Approved By: 

Date: 11-3-17